

DISTRIBUTION SYSTEM COLIFORM MONITORING REPORT

SYSTEM NAME: MARINA COAST WATER DISTRICT WATER SYSTEM

SYSTEM NUMBER: CA2710017

REPORTING PERIOD: July 2025

LABORATORY: Monterey Bay Analytical

ELAP CERTIFICATE: 2385

METHOD: SM9223B – Colilert

GROUP	DATE COLLECTED	COLLECTED BY	EMPLOYED BY	SAMPLE NUMBER	SAMPLING POINT	SAMPLE TYPE	TOTAL COLIFORM	E. coil	Chlorine Residual
C	7-July-2025	Goncalves	MCWD	C1	DS - 3106 Flower Circle	Routine	Absent	Absent	0.94
	7-July-2025	Goncalves	MCWD	C2	DS - 3073 Zanetta Drive	Routine	Absent	Absent	0.92
	7-July-2025	Goncalves	MCWD	C3	DS - 3196 Melanie Road	Routine	Absent	Absent	0.93
	7-July-2025	Goncalves	MCWD	C4	DS - 3345 Cardoza Avenue	Routine	Absent	Absent	0.65
	7-July-2025	Goncalves	MCWD	C5	DS - 3271 Cove Way	Routine	Absent	Absent	0.87
	7-July-2025	Goncalves	MCWD	C6	DS - 314 Ardennes Circle	Routine	Absent	Absent	1.03
	7-July-2025	Goncalves	MCWD	C7	DS - 325 Buna Road	Routine	Absent	Absent	1.41
	7-July-2025	Goncalves	MCWD	C8	DS - 207 Rome Road	Routine	Absent	Absent	0.73
	7-July-2025	Goncalves	MCWD	C9	DS - Airport Vault	Routine	Absent	Absent	1.05
	7-July-2025	Goncalves	MCWD	C10	DS - 4790 Peninsula Point Drive	Routine	Absent	Absent	1.04
D	14-July-2025	Watson	MCWD	D1	DS - 263 Grant Street	Routine	Absent	Absent	1.01
	14-July-2025	Watson	MCWD	D2	DS - 3020 Jean Street	Routine	Absent	Absent	0.93
	14-July-2025	Watson	MCWD	D3	DS - 266 Cosky Drive	Routine	Absent	Absent	0.86
	14-July-2025	Watson	MCWD	D4	DS - 3180 Ninole Drive	Routine	Absent	Absent	0.88
	14-July-2025	Watson	MCWD	D5	DS - 3203 DeForest Road	Routine	Absent	Absent	1.28
	14-July-2025	Watson	MCWD	D6	DS - 1701 Eichelberger Court	Routine	Absent	Absent	0.95
	14-July-2025	Watson	MCWD	D7	DS - 3071 Wittenmyer Court	Routine	Absent	Absent	0.98
	14-July-2025	Watson	MCWD	D8	DS - 11th Street-Imjin Road	Routine	Absent	Absent	1.01
	14-July-2025	Watson	MCWD	D9	DS - 110 Nijmegen Road	Routine	Absent	Absent	0.95
	14-July-2025	Watson	MCWD	D10	DS - 180 Okinawa Road	Routine	Absent	Absent	0.91
A	21-July-2025	Goncalves	MCWD	A1	DS - 3324 Abdy Way	Routine	Absent	Absent	0.99
	21-July-2025	Goncalves	MCWD	A2	DS - 3020 King Circle	Routine	Absent	Absent	0.79
	21-July-2025	Goncalves	MCWD	A3	DS - 3166 Crescent Avenue	Routine	Absent	Absent	1.41
	21-July-2025	Goncalves	MCWD	A4	DS - 221 Cypress Avenue	Routine	Absent	Absent	0.88
	21-July-2025	Goncalves	MCWD	A5	DS - 3106 Bayer Street	Routine	Absent	Absent	0.95
	21-July-2025	Goncalves	MCWD	A6	DS - 5871 Imjin Road	Routine	Absent	Absent	0.71
	21-July-2025	Goncalves	MCWD	A7	DS - 3570 3rd Street	Routine	Absent	Absent	0.66
	21-July-2025	Goncalves	MCWD	A8	DS - 326 Carentan Road	Routine	Absent	Absent	1.03
	21-July-2025	Goncalves	MCWD	A9	DS - 180 Bataan Road	Routine	Absent	Absent	0.97
	21-July-2025	Goncalves	MCWD	A10	DS - 5060 Fitch Middle School	Routine	Absent	Absent	0.87
B	28-July-2025	Goncalves	MCWD	B1	DS - 3076 Clarke Place	Routine	Absent	Absent	0.91
	28-July-2025	Goncalves	MCWD	B2	DS - 3136 Lynscoot Drive	Routine	Absent	Absent	1.03
	28-July-2025	Goncalves	MCWD	B3	DS - 3270 Michael Drive	Routine	Absent	Absent	0.96
	28-July-2025	Goncalves	MCWD	B4	DS - 3100 Everett Circle	Routine	Absent	Absent	1.29
	28-July-2025	Goncalves	MCWD	B5	DS - 300 Quebrada del Mar Road	Routine	Absent	Absent	1.12
	28-July-2025	Goncalves	MCWD	B6	DS - 3438 Spotsylvania Court	Routine	Absent	Absent	1.05
	28-July-2025	Goncalves	MCWD	B7	DS - 6th Avenue 53	Routine	Absent	Absent	1.04
	28-July-2025	Goncalves	MCWD	B8	DS - 4235 Gigling Road	Routine	Absent	Absent	0.98
	28-July-2025	Goncalves	MCWD	B9	DS - 1830 Cassino Road	Routine	Absent	Absent	0.97
	28-July-2025	Goncalves	MCWD	B10	DS - Seaside High School	Routine	Absent	Absent	0.89

Marina Coast Water District-WS BSSP, Dec. 5, 2006, Amended November 30, 2012. Amended September 21, 2021. Group sampling is on a weekly rotation.

August 6, 2025

Joe Pineda
Operations & Maintenance Supervisor

Date of Report